

Local Government (Water Pollution) Act 1977 &
Local Government (Water Pollution) Amendment) Act 1990

LICENCE TO DISCHARGE TRADE OR SEWAGE
EFFLUENTS TO GROUND WATERS

LOCAL AUTHORITY Sligo County Council Ref. No.: SS 23/435

TO: Knockmuldowney Restaurant Co. Ltd.,
c/o C.S. Pringle,
Consulting Engineer,
Glenview,
Monaghan.

That Sligo County Council in exercise of the power conferred on it by the Local Government (Water Pollution) Act 1977 and the Local Government (Water Pollution) Amendment) Act 1990, hereby grants a licence to discharge sewage effluent to ground waters

FROM: Markree Castle Hotel, Collooney, Co. Sligo.

TO: ground waters at Collooney, Co. Sligo

Subject to the following conditions:-

1. — The Company shall not discharge or cause or permit to be discharged to the ground.
 - (a) any effluent with a pH less than 6 or greater than 8
 - (b) any effluent with a B.O.D greater than 20mg/l.
 - (c) any effluent with a T.S.S. greater than 30mg/l.
 - (d) any effluent with NH₃-N greater than 2.5 mg/l.
 - (e) any effluent with Nitrate-N greater than 20 mg/l
2. Provision shall be provided for sampling treated effluent.

Contd/...

3. All oils, grease and fats shall be removed prior to treatment by the provision of an independent grey water pipeline system with grease trap from kitchen area discharged independently to percolation area.
4. In accordance with the Local Government (Water Pollution) Act, 1977 as amended the conditions of this licence may be reviewed after 3 years or such earlier date as circumstances may require.
5. The company shall pay an annual charge of £100 updated in accordance with the consumer price index. The charge is in respect of monitoring.

Dated this 10th day of Jan, 1997.

Signed: 
ADMINISTRATIVE OFFICER