

County	Name of Water Supply	Scheme Code	Population Served	Volume Supplied (m3/day)	Proposed Action Programme	Proposed Date of Completion of Action Programme (This is the date by which works are complete. There will be a further period to demonstrate the effectiveness of works before the supply is removed from the RAL.)	RAL Category									
							Inadequate Treatment for Cryptosporidium	Inadequate Treatment - Inadequate Disinfection	Failed to meet E coli/Enterococci standard in the Drinking Water Regulations	Elevated Levels of THMs above the standard in the Drinking Water Regulations	Elevated Levels of Pesticides above the standard in the Drinking Water Regulations	Supply identified by the HSE where further investigation or improvement may be required	Excessive levels of aluminium in the treated water	Poor turbidity removal	EPA Audit Observation - Treatment and Management Issues	
Carlow	Carlow North Regional	0100PUB1142	7,866	7,027	Upgrade of water treatment plant	June 2024										Y
Cavan	Belturbet	0200PUB0108	1,726	638	Complete catchment-focussed engagement actions involving Uisce Éireann and the relevant stakeholders (as set out in Uisce Éireann's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction required compliance by December 2020. Monitoring underway to verify effectiveness of the action programme.					Y					
Clare	Corofin	0300PUB1010	1,310	336	Upgrade of water treatment plant	Complete and awaiting verification of the effectiveness of the action programme							Y			Y
Clare	Ennistymon RWS	0300PUB1004	6,703	6,083	Upgrade of water treatment plant	December 2023										Y
Clare	West Clare RWS (New WTP)	0300PUB1066	10,093	13,608	Upgrade of water treatment plant	EPA Direction required compliance by December 2021. Upgrade of Water Treatment Plant completed. Reservoir cleaning/pipe flushing ongoing.				Y						Y
Clare	West Clare RWS (Old WTP)	0300PUB1022	4,028	2,615	Existing plant to be replaced with new package plant.	December 2026				Y						Y
Cork	Killavullen	0500PUB1310	810	423	Rationalisation of supply	December 2024								Y		
Cork	Mitchelstown North	0500PUB1506	2,389	1,353	Installation of GAC system for removal of organics to minimise THM formation	June 2025				Y						
Cork	Ballyclough & Mount North	0500PUB1316	1,977	1,135	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann	Y									
Cork	Castletownbere	0500PUB4205	2,424	2,151	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann				Y						
Cork	Fermoy	0500PUB1207	7,447	3,321	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann	Y									
Cork	Glashaboy	0500PUB3303	22,771	17,982	Upgrade of water treatment plant	June 2025										Y
Cork	Macroom	0500PUB2307	4,218	1,498	Upgrade water treatment plant	June 2025										Y
Cork	Whiddy Island	0500PUB4108	45	16	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann						Y				
Cork	Whitegate Regional	0500PUB2407	9,482	5,042	Upgrade of water treatment plant	December 2025								Y		Y
Donegal	Lettermacaward	0600PUB1069	2,266	1731	Upgrade of water treatment plant.	December 2024				Y			Y			
Donegal	Glenties-Ardara	0600PUB1070	3,518	1,668	Installation of membrane filtration system to address the raw water colour and organic content, and minimise THM formation.	September 2024				Y						
Donegal	Milford	0600PUB1050	2,560	1,953	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann				Y						
Galway	Inisboffin	1200PUB1024	165	217	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann										Y
Kerry	Aughacasia	1300PUB1022	338	329	Installation of GAC post slow sand filtration.	Complete and awaiting verification of the effectiveness of the action programme				Y						
Kerry	Cahersiveen	1300PUB1050	1,699	1,362	Crypto risk: Installation of UV disinfection. THM risk: Installation of GAC post slow sand filtration.	Crypto risk: June 2023. THM risk: EPA Direction requires compliance by December 2023. IW proposed completion date is June 2024.	Y			Y						
Kerry	Caragh Lake	1300PUB1046	1,886	1,181	Upgrade of pressure filtration and installation of GAC	Complete and awaiting verification of the effectiveness of the action programme.				Y						Y
Kerry	Listowel Regional Public Water Supply	1300PUB1204	14464	9,400	Develop supplementary groundwater source	To be submitted by Uisce Éireann				Y						
Kerry	Kilgarvan	1300PUB1059	630	310	Installation of GAC post slow sand filters	December 2024				Y						
Kerry	Lyreacrompane	1300PUB1009	2,561	997	Develop supplementary groundwater source	To be submitted by Uisce Éireann				Y						
Kildare	Barrow supply (Srowland WTP) ¹	1400PUB1060	81,553	20,821	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann										Y
Kilkenny	Callan	1500PUB1003	2763	1005	Installation of UV disinfection	March 2023	Y									
Kilkenny	Kilkenny City (Radestown) WS	1500PUB1010	14,483	4,573	Abandon source of water supply and replace with Troyswood PWS	EPA Direction requires compliance by 30th June 2022. Uisce Éireann has now provided a completion date of March 2024.				Y						
Kilkenny	Pilltown-Fiddown	1500PUB1013	2,973	622	Develop new groundwater source	March 2023	Y									
Limerick	Limerick City Environs	1900PUB1032	114,864	42,983	Optimisation of plant and network to reduce risk of THM formation.	December 2023				Y						
Limerick	Foynes/Shannon Estuary PWS	1900PUB1027	7,215	19,510	To be submitted by Uisce Éireann	EPA Direction requires compliance by April 2023					Y					

Longford	Granard	2000PUB1006	2,447	1,338	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann					Y						
Longford	Longford Central	2000PUB1010	15,979	7,535	Upgrade of water treatment plant.	Uisce Éireann to provide a date for compliance with the THM parametric value of 100 ug/L.					Y						
Louth	Greenmount	2100PUB1002	3,955	1,089	Upgrade of treatment facilities.	September 2026											Y
Louth	Tallanstown	2100PUB1005	1,932	424	Replacement of supply with Cavanhill PWS	EPA Direction required compliance by December 2020. Uisce Éireann has provided a completion date of October 2023.								Y			Y
Mayo	Louisburgh	2200PUB1020	885	319	Abandon source and connect to Westport PWS (via Murrisk Group Water Scheme)	To be submitted by Uisce Éireann											Y
Mayo	Newport PWS	2200PUB1022	684	306	Complete catchment-focussed engagement actions involving Uisce Éireann and the relevant stakeholders (as set out in Uisce Éireann's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction required compliance by December 2021. Monitoring underway to verify effectiveness of the action programme.					Y						
Meath	Batterstown	2300PUB1068	96	38	Replace source and connect to Dunshaughlin PWS to address bromate exceedances	June 2023							Y				
Meath	Drumcondrath	2300PUB1005	1,227	581	Develop new groundwater sources and upgrade water treatment plant	EPA Direction requires compliance by June 2023. Uisce Éireann has provided a proposed completion date of June 2026.	Y				Y						
Meath	Navan - Mid Meath Kilcarn PWS	2300PUB1051	6,412	1,569	Replace DAFF with new CFC and filtration.	June 2026					Y						
Meath	Trim PWS	2300PUB1009	11,187	3,311	Upgrade of water treatment plant	December 2025											Y
Offaly	Clara/Ferbane RWSS	2500PUB1003	7,341	2,354	Upgrade of water treatment plant	June 2024					Y						
Roscommon	North East Regional	2600PUB1030	7,803	3,960	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann					Y						
Tipperary	Borrisokane	2800PUB1002	1,841	788	Installation of UV disinfection	June 2023	Y										
Tipperary	Clonmel Poulavanogue	2900PUB0109	2,435	1,889	Inadequate Contact Time on portion of supply risk: Connection of affected properties to new water main. Crypto risk: Rationalisation of WTP	Inadequate contact time risk: June 2023. Crypto risk: December 2026	Y	Y									
Tipperary	Galtee Regional	2900PUB0130	11,379	8,970	Further upgrade of water treatment plant	December 2026								Y	Y	Y	
Tipperary	Kilcash	2900PUB0147	207	78	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann	Y										
Tipperary	Nenagh Regional	2800PUB1008	14,005	6,344	Installation of pH correction to optimise coagulation stage	January 2023					Y						
Tipperary	Roscrea	2800PUB1009	6,223	1,755	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann	Y										
Tipperary	Templetuohy	2800PUB1013	808	261	To be submitted by Uisce Éireann	To be submitted by Uisce Éireann	Y										
Waterford	Graiguenageeha	3100PUB1051	43	14	Abandon source and connect to Stradbally PWS	December 2024		Y									
Waterford	Dungarvan	3100PUB1039	12,893	5,755	Construction of new water treatment plant	September 2026										Y	
Waterford	Kereen	3100PUB1057	28	106	Abandon source and connect to Cappoquin PWS	March 2023										Y	Y
Wexford	Enniscorthy	3300PUB1491	11,288	3,413	Upgrade of water treatment plant	June 2025	Y										Y
Wexford	Clonroche	3300PUB1452	588	250	Complete catchment-focussed engagement actions involving Uisce Éireann and the relevant stakeholders (as set out in Uisce Éireann's response to EPA Direction) to achieve compliance with the limits for pesticides	EPA Direction required compliance by January 2021. Monitoring underway to verify the effectiveness of the action programme.					Y						
Wexford	Wexford Town	3300PUB1669	20,791	6,684	Upgrade of water treatment plant	December 2024											Y
Wicklow	Aughrim / Annacurra	3400PUB1023	1,588	364	Abandon source and connect to Arklow water treatment plant	EPA Direction requires compliance by December 2023					Y						
Wicklow	Ballymorris	3400PUB1076	17	5	Abandon source and connect to Arklow water treatment plant	December 2023		Y								Y	

1. Srowland WTP fully feeds the Barrow supply and partially feeds the Barrow Poulaphouca PWS (1400PUB1070), Monasterevin PWS (1400PUB1020) and Rathangan PWS (1400PUB1041).