



System Procedure
Monthly Status Report
Cliffs of Moher, April 2021

Date	20/05/2021
Description	Initial Issue
Approved By	
Originator	



Cliffs of Moher Wastewater Treatment Plant
Operational Report
for
April 2021



System Procedure
Monthly Status Report
Cliffs of Moher, April 2021

Date	20/05/2021
Description	Initial Issue
Approved By	[Redacted]
[Redacted]	[Redacted]

1. INTRODUCTION.....	3
2. EXECUTIVE SUMMARY	3
3. GRAPHICAL PRESENTATION OF DATA.....	4
4. PROCESS AND OPERATIONAL ISSUES.....	7
5. HEALTH & SAFETY ISSUES.....	7
6. COMPLAINTS REGISTER	8
7. EQUIPMENT CALIBRATION RECORDS	8
8. WASTE & SLUDGE DISPOSAL RECORDS.....	9
9. ANALYSIS RESULTS FOR MIXED LIQUOR.....	9
10. ANALYSIS RESULTS FOR INFLUENT	10
11. ANALYSIS RESULTS FOR FINAL EFFLUENT	10



System Procedure
Monthly Status Report
Cliffs of Moher, April 2021

Date	20/05/2021
Description	Initial Issue
Approved By	
Originator	

1. Introduction

This report covers the period of April 2021 for the operation of Cliffs of Moher Wastewater Treatment Plant by EPS, on behalf of Cliffs of Moher Visitor Experience.

2. Executive Summary

The plant processed 121 m³ of effluent for the month, at an average daily flow of approximately 4 m³/day during February.

There were no influent sample taking for the month of April as there are insufficient flows been processed through the plant. The Plant Operator has been adding Water at the Inlet Screen and Molasses to sustain the MLSS Levels at the plant.

The final effluent results from the 27th of April were non-compliant as per contract conditions for BOD, Ammonia and Total Phosphorus. All other results were compliant.

The inlet pump was repaired on the 14th of April.


3. Graphical Presentation of Data

Table of total daily flows for April 2021 MBR's			
Date	MBR Flow #1 (m ³)	MBR Flow #2 (m ³)	Total Flow
01/04/2021	4	0	4
02/04/2021	4	0	4
03/04/2021	4	0	4
04/04/2021	4	0	4
05/04/2021	4	0	4
06/04/2021	4	0	4
07/04/2021	3	0	3
08/04/2021	0	0	0
09/04/2021	0	0	0
10/04/2021	0	0	0
11/04/2021	0	0	0
12/04/2021	0	0	0
13/04/2021	9	0	9
14/04/2021	5	0	5
15/04/2021	5	0	5
16/04/2021	5	0	5
17/04/2021	5	0	5
18/04/2021	4	0	4
19/04/2021	4	0	4
20/04/2021	5	0	5
21/04/2021	4	0	4
22/04/2021	5	0	5
23/04/2021	5	0	5
24/04/2021	6	0	6
25/04/2021	6	0	6
26/04/2021	5	0	5
27/04/2021	5	0	5
28/04/2021	5	0	5
29/04/2021	5	0	5
30/04/2021	6	0	6
Average	4	0	4



System Procedure
Monthly Status Report
Cliffs of Moher, April 2021

Date	20/05/2021
Description	Initial Issue
Approved By	[Redacted]
Originator	[Redacted]





System Procedure
Monthly Status Report
Cliffs of Moher, April 2021

Date	20/05/2021
Description	Initial Issue
Approved By	
Originator	

Table of Cumulative Hours Run

	30/03/2021	30/04/2021	Ave Daily Usage Hours
Inlet screen	31,288	31,291	0.10
Inlet pump 1	4,318	4,326	0.28
Inlet pump 2	5,142	5,142	0.00
Balance tank 1,pump 1	4,756	4,766	0.34
Balance tank 1,pump 2	6,952	6,952	0.00
Anoxic mixer no. 1	89,724	90,467	25.62
Anoxic mixer no. 2	55,422	55,422	0.00
Membrane pump 1 (RAS)	82,571	83,315	25.66
Membrane pump 2 (RAS)	51,877	51,877	0.00
Sludge holding tank mixer	4,072	4,072	0.00
Odour fan no. 1	59,806	59,806	0.00
Odour fan no. 2	62,544	63,289	25.69
Forward feed no.1	10,368	10,368	0.00
Forward feed no.2	16,186	16,202	0.55
Drainage pump	1,065	1,066	0.03
Balance tank 2, pump no.1	7,001	7,001	0.00
Balance tank 2, pump no.2	16,896	16,896	0.00
Air Blower 1	20,109	20,109	0.00
Air Blower 2	57,896	57,896	0.00
Air Blower 3	94,128	94,862	25.31
Air compressor	7,621	8,366	25.69
Ultraviolet system	60,978	60,978	0.00



System Procedure
Monthly Status Report
Cliffs of Moher, April 2021

Date	20/05/2021
Description	Initial Issue
Approved By	[Redacted]

4. Process and Operational Issues

Process and Operational Issues		
Date	Description of Process Operational Issue	Implemented by
	Nothing this month	

5. Health & Safety Issues

Site Safety Induction Report				
Contractor Name		Contract Number		
Date	Inductor	Inductee	Inductee Signature	Inductee Company
No Site Safety Inductions were undertaken during this monitoring period				

Health & Safety Statistics Report			
Plant Manager	[Redacted]	Date	May-21
For Period	April-21		
Site Involved	Cliffs of Moher WWTP		
Category 1: Covers Fatalities and major Injuries Category 2: Covers lost time accident resulting in more than 3 days absence Category 3: Covers lost time accidents resulting in 3 days absence or less Major Incident: Accident not covered by categories 1 to 3			

Direct Employees					
Number of Employees:	1		Exposure Hours:	32hrs	
	Category 1	Category 2	Category 3	Major Incident	Near Miss
Number of Accidents	0	0	0	0	0
Days lost					

Direct Employees					
Number of Employees:			Exposure Hours:		
Subcontractors on Site					
	Category 1	Category 2	Category 3	Major Incident	Near Miss
Number of Accidents	0	0	0	0	0
Days lost					

ARP7/4 INSERTED HERE IF AN ACCIDENT OR INCIDENT HAS OCCURED (USE PHOTOCOPY OF EPS FORM HS002)



Date	20/05/2021
Description	Initial Issue
Approved By	
Originator	

6. Complaints Register

No written complaints were received during this monitoring period

Complaints Register			
Complainant's Name		Date	
Nature of Complaint			
Acknowledgement of Complaint	Author of Acknowledgement	Date Sent	
Cause of Complaint			
Action taken to Resolve cause of Complaint:			
Final Outcome Report	Author of Final Outcome Report	Date Forwarded to Local Authority	

7. Equipment Calibration Records

Equipment Calibration Record						
Date	Equipment Description	Serial No.	Calibrated By (Name & Company)	Next Calib. Due	Calib. Cert Recd.	Comment
Nothing to report						



System Procedure
Monthly Status Report
Cliffs of Moher, April 2021

Date	20/05/2021
Description	Initial Issue
Approved By	
Originator	

8. Waste & Sludge Disposal Records

Non-Sludge Waste Disposal Record					
Date	Waste Description	Amount removed	Removed By (Name & Company)	Destination Address	Receipt for Acceptance of Waste

Outgoing Sludge Record					
Batch No.	Date	Destination of Product	Type of Product	Quantity of Product	Contact at Destination
					Nothing to Report

9. Analysis Results for Mixed Liquor

Analysis Results for Mixed Liquor (mg/l)				
Date	MLSS MBR 1	Anoxic 1	MLSS MBR2	Anoxic 2
20/04/2021	10,660 mg/l			



System Procedure
Monthly Status Report
Cliffs of Moher, April 2021

Date	20/05/2021
Description	Initial Issue
Approved By	[REDACTED]
Originator	[REDACTED]

10. Analysis Results for Influent

Analysis Results for influent							
Date	BOD (mg/l O ₂)	COD (mg/l O ₂)	SS (mg/l)	Total Nitrogen (mg/l)	Ammonia (mg/l)	Total Phosphorous (mg/l)	pH
Maximum for month	0	0	0		0	0.0	0.0
Average for month	#DIV/0!	#DIV/0!	#DIV/0!		#DIV/0!	#DIV/0!	#DIV/0!
Design values	220		170		105	11.2	

11. Analysis Results for Final Effluent

Analysis Results for Final Effluent							
Date	BOD (mg/l O ₂)	COD (mg/l O ₂)	SS (mg/l)	Total Nitrogen (mg/l)	Ammonia (mg/l)	Total Phosphorous (mg/l)	pH
27/04/2021	20	89	5		12	5.53	7.32
Average for month	20.0	89	5.0	N/A	12.00	5.53	7.3
Licence limit	15	100	15	15	5	2	6 to 9