

Date	15/08/2021		
Description	Initial Issue		
Approved By			



Cliffs of Moher Wastewater Treatment Plant

Operational Report for July 2021



Date	15/08/2021	
Description	Initial Issue	
Approved By		
Originator		

1.	INTRODUCTION	3
2.	EXECUTIVE SUMMARY	3
3.	GRAPHICAL PRESENTATION OF DATA	4
4.	PROCESS AND OPERATIONAL ISSUES	7
5.	HEALTH & SAFETY ISSUES	7
6.	COMPLAINTS REGISTER	8
7.	EQUIPMENT CALIBRATION RECORDS	8
8.	WASTE & SLUDGE DISPOSAL RECORDS	9
9.	ANALYSIS RESULTS FOR MIXED LIQUOR	9
10.	ANALYSIS RESULTS FOR INFLUENT	10
11.	ANALYSIS RESULTS FOR FINAL EFFLUENT	10



Date	15/08/2021				
Description	Initial Issue				
Approved By					
Originator					

1. Introduction

This report covers the period of July 2021 for the operation of Cliffs of Moher Wastewater Treatment Plant by EPS, on behalf of Cliffs of Moher Visitor Experience.

2. Executive Summary

The plant processed 332 m3 of effluent for the month, at an average daily flow of approximately 11 m³/day during July.

The Plant Operator has been adding Water at the Inlet Screen and Molasses to sustain the MLSS Levels at the plant.

The final effluent results from the 13th of July were non-compliant as per contract conditions for Total Phosphorus. All other results were compliant.



Date	15/08/2021
Description	Initial Issue
Approved By	
Originator	

3. Graphical Presentation of Data


Table o	Table of total daily flows for June 2021 MBR's				
Date	MBR Flow #1 (m ³)	MBR Flow #2 (m ³)	Total Flow		
01/07/2021	16	0	16		
02/07/2021	10	0	10		
03/07/2021	10	0	10		
04/07/2021	7	0	7		
05/07/2021	8	0	8		
06/07/2021	15	0	15		
07/07/2021	14	0	14		
08/07/2021	6	0	6		
09/07/2021	5	0	5		
10/07/2021	10	0	10		
11/07/2021	10	0	10		
12/07/2021	10	0	10		
13/07/2021	9	0	9		
14/07/2021	1	0	1		
15/07/2021	13	0	13		
16/07/2021	14	0	14		
17/07/2021	7	0	7		
18/07/2021	7	0	7		
19/07/2021	8	0	8		
20/07/2021	13	0	13		
21/07/2021	13	0	13		
22/07/2021	13	0	13		
23/07/2021	4	0	4		
24/07/2021	14	0	14		
25/07/2021	7	0	7		
26/07/2021	21	0	21		
27/07/2021	22	0	22		
28/07/2021	15	0	15		
29/07/2021	16	0	16		
30/07/2021	7	0	7		
31/07/2021	8	0	8		
Average	11	0	11		

Page 4 of 10



Date	15/	/08/2021
Description	Init	tial Issue
Approved By		

Total Flow



Page 5 of 10



Date	15/08/2021		
Description	Initial Issue		
Approved By			

Table of Cumulative Hours Run

	29/06/2021	30/07/2021	Ave Daily Usage
			Hours
Inlet screen	31,343	31,398	1.90
Inlet pump 1	4,353	4,374	0.72
Inlet pump 2	5,142	5,142	0.00
Balance tank 1,pump 1	4,815	4,917	3.52
Balance tank 1,pump 2	6,952	6,954	0.07
Anoxic mixer no. 1	91,898	92,649	25.90
Anoxic mixer no. 2	55,422	55,422	0.00
Membrane pump 1 (RAS)	84,620	85,368	25.79
Membrane pump 2 (RAS)	51,877	51,877	0.00
Sludge holding tank mixer	4,072	4,072	0.00
Odour fan no. 1	59,806	59,806	0.00
Odour fan no. 2	64,720	65,471	25.90
Forward feed no.1	10,368	10,368	0.00
Forward feed no.2	16,264	16,308	1.52
Drainage pump	1,067	1,072	0.17
Balance tank 2, pump no.1	7,001	7,003	0.07
Balance tank 2, pump no.2	16,896	16,896	0.00
Air Blower 1	20,109	20,109	0.00
Air Blower 2	57,896	57,896	0.00
Air Blower 3	96,289	97,016	25.07
Air compressor	9,797	10,549	25.93
Ultraviolet system	60,978	60,978	0.00

Page 6 of 10



Date	15/08/2021
Description	Initial Issue
Approved By	

4. Process and Operational Issues

Process and Operational Issues			
Date Description of Process Operational Issue		Implemented by	
Nothing this month			

5. Health & Safety Issues

Site Safety Induction Report					
Contractor Name Contract Number					
Date	Inductor	Inductee	Inductee Signature	Inductee Company	
No	No Site Safety Inductions were undertaken during this monitoring period				

	Health & Sa	fety Statisti	ics Report	
Plant Manager			Date	August-21
For Period	July-21			
Site Involved	Cliffs of Moher WW	P		
Category 1: Covers Fatalit Category 2: Covers lost tin	ies and major Injuries ne accident resulting in more than 3	days absence		
0 ,	ne accidents resulting in 3 days absort covered by categories 1 to 3	nce or less		

	Direct Employees					
Number of Employees: 1		Exposure Hours:		32hrs		
	Category 1	Category 2	Category 3	Major Incident	Near Miss	
Number of						
Accidents	0	0	0	0		0
Days lost						

		Direct E	Employees	;		
Number of Emp	loyees:		Exposure Hours:			
Subcontractors						
on Site						
	Category 1	Category 2	Category 3	Major Incident	Near Miss	
Number of						
Accidents	0	0	0	0	(0
Days lost						

ARP7/4 INSERTED HERE IF AN ACCIDENT OR INCIDENT HAS OCCUERD (USE PHOTOCOPY OF EPS FORM HS002)

Page 7 of 10	



Date	15/08/2021	I
Description	Initial Issue]
Approved By		1
Originator		1

6. Complaints Register

No written complaints were received during this monitoring period

	Complaints Register			
Complainant's Name	Date			
Nature of Complaint				
Acknowledgement of Complaint	Author of Acknowledgement	Date Sent		
Cause of Complaint				
Action taken to Resolve cause of Complaint:				
Final Outcome Report	Author of Final Outcome Report	Date Forwarded to Local Authority		

7. Equipment Calibration Records

	Equipment Calibration Record					
Date	Equipment	Serial No.		Next Calib.	Calib. Cert	Comment
Date	Description	Serial No.	(Name & Company)	Due	Recd.	Comment
	Nothing to report					
					·	



Date	15/08/2021
Description	Initial Issue
Approved By	В

8. Waste & Sludge Disposal Records

	Non-Sludge Waste Disposal Record					
Date	Waste Description	Amount removed	Removed By (Name & Company)	Destination Address	Receipt for Acceptance of Waste	
				·		

	Outgoing Sludge Record				
Batch No.	Date	Destination of Product	Type of Product	Quantity of Product	Contact at Destination
					Nothing to Report

9. Analysis Results for Mixed Liquor

Analysis Results for Mixed Liquor (mg/l)				
Date	MLSS MBR 1	Anoxic 1	MLSS MBR2	Anoxic 2

Page 9 of 10



Date	15/08/2021
Description	Initial Issue
Approved By	
Originator	

10. Analysis Results for Influent

Analysis Results for influent												
Date	BOD (mg/l O ₂)	COD (mg/l O ₂)	SS (mg/l)	Total Nitrogen (mg/l)	Ammonia (mg/l)	Total Phosphorous (mg/l)	рН					
13/07/2021	391	1,110	370		263	20.4	9.0					
Maximum for month	391	1,110	370		263	20.4	9.0					
Average for month	391	1,110	370		263	20.4	9.0					
Design values	220		170		105	11.2						

11. Analysis Results for Final Effluent

Analysis Results for Final Effluent											
Date	BOD (mg/l O ₂)	COD (mg/l O ₂)	SS (mg/l)	Total Nitrogen (mg/l)	Ammonia (mg/l)	Total Phosphorous (mg/l)	рН				
13/07/2021	2	35	6		0.285	11.7	6.37				
Average for month	2.0	35	6.0	N/A	0.29	11.70	6.4				
Licence limit	15	100	15	15	5	2	6 to 9				

Page 10 of 10