

Date	17/11/2	2021
Description	Initial Is	ssue
Approved By		
Originator		



Cliffs of Moher Wastewater Treatment Plant

Operational Report for October 2021



Date	17/11/2021
Description	Initial Issue
Approved By	
Originator	

1.	INTRODUCTION	3
	EXECUTIVE SUMMARY	
3.	GRAPHICAL PRESENTATION OF DATA	4
4.	PROCESS AND OPERATIONAL ISSUES	7
5.	HEALTH & SAFETY ISSUES	7
6.	COMPLAINTS REGISTER	8
7.	EQUIPMENT CALIBRATION RECORDS	8
8.	WASTE & SLUDGE DISPOSAL RECORDS	9
9.	ANALYSIS RESULTS FOR MIXED LIQUOR	9
10.	ANALYSIS RESULTS FOR INFLUENT	10
11.	ANALYSIS RESULTS FOR FINAL EFFLUENT	10



Date	17/11/2021
Description	Initial Issue
Approved By	
Originator	

1. Introduction

This report covers the period of October 2021 for the operation of Cliffs of Moher Wastewater Treatment Plant by EPS, on behalf of Cliffs of Moher Visitor Experience.

2. Executive Summary

The plant processed 337 m3 of effluent for the month, at an average daily flow of approximately 11 m³/day during August.

The influent results for October 4th showed that the Incoming wastewater was not in compliance with the plant design specification for BOD, Suspended Solids, Ammonia and Total Phosphorus which was in excess of design criteria.

The final effluent results from the 4th of October show that Total Phosphorus was not in compliance as per contract conditions.

The Plant Operator has been adding Water at the Inlet Screen and Molasses to sustain the MLSS Levels at the plant.



Date	17/11/2021
Description	Initial Issue
Approved By	
Originator	

3. Graphical Presentation of Data


Table of	total daily flows	for October 202	1 MBR's
Date	MBR Flow #1 (m ³)	MBR Flow #2 (m ³)	Total Flow
01/10/2021	8	0	8
02/10/2021	8	0	8
03/10/2021	9	0	9
04/10/2021	13	0	13
05/10/2021	13	0	13
06/10/2021	7	0	7
07/10/2021	8	0	8
08/10/2021	12	0	12
09/10/2021	12	0	12
10/10/2021	15	0	15
11/10/2021	15	0	15
12/10/2021	5	0	5
13/10/2021	6	0	6
14/10/2021	9	0	9
15/10/2021	15	0	15
16/10/2021	15	0	15
17/10/2021	13	0	13
18/10/2021	13	0	13
19/10/2021	8	0	8
20/10/2021	8	0	8
21/10/2021	12	0	12
22/10/2021	12	0	12
23/10/2021	12	0	12
24/10/2021	13	0	13
25/10/2021	11	0	11
26/10/2021	11	0	11
27/10/2021	14	0	14
28/10/2021	14	0	14
29/10/2021	7	0	7
30/10/2021	8	0	8
31/10/2021	11	0	11
Average	11	0	11

Page 4 of 10



Date	17/11/2021
Description	Initial Issue
Approved By	
Originator	

Total Flow





Date	17/11/2021	
Description	Initial Issue	
Approved By		
Originator		

Table of Cumulative Hours Run

	29/09/2021	31/10/2021	Ave Daily Usage
			Hours
Inlet screen	31,555	31,610	1.90
Inlet pump 1	4,415	4,428	0.45
Inlet pump 2	5,159	5,170	0.38
Balance tank 1,pump 1	5,257	5,403	5.03
Balance tank 1,pump 2	6,959	6,959	0.00
Anoxic mixer no. 1	94,068	94,818	25.86
Anoxic mixer no. 2	55,422	55,422	0.00
Membrane pump 1 (RAS)	86,816	87,565	25.83
Membrane pump 2 (RAS)	51,877	51,877	0.00
Sludge holding tank mixer	4,072	4,072	0.00
Odour fan no. 1	59,806	59,806	0.00
Odour fan no. 2	66,936	67,687	25.90
Forward feed no.1	10,368	10,368	0.00
Forward feed no.2	16,410	16,453	1.48
Drainage pump	1,079	1,088	0.31
Balance tank 2, pump no.1	7,004	7,004	0.00
Balance tank 2, pump no.2	16,896	16,896	0.00
Air Blower 1	20,109	20,109	0.00
Air Blower 2	57,896	57,896	0.00
Air Blower 3	98,460	99,210	25.86
Air compressor	12,013	12,764	25.90
Ultraviolet system	60,978	60,978	0.00

Page 6 of 10



Date	17/11/2021	
Description	Initial Issue	
Approved By		
Originator		

4. Process and Operational Issues

Process and Operational Issues			
Date Description of Process Operational Issue		Implemented by	
Nothing this month			

5. Health & Safety Issues

Site Safety Induction Report				
Contract Number Contract Number				
Date	Inductor	Inductee	Inductee Signature	Inductee Company
No	No Site Safety Inductions were undertaken during this monitoring period			

Health & Safety Statistics Report						
Plant Manager		_	Date	November-21		
For Period	October-21	_				
Site Involved	Cliffs of Moher WWTP	-				
Category 1: Covers Fatalit	ies and major Injuries					
Category 2: Covers lost tin	ne accident resulting in more than 3 days	absence				
Category 3: Covers lost time accidents resulting in 3 days absence or less						
Major Incident: Accident no	ajor Incident: Accident not covered by categories 1 to 3					

Direct Employees							
Number of Emp	1	Exposure Hours:		32hrs			
	Category 1	Category 2	Category 3	Major Incident	Near Miss		
Number of							
Accidents	0	0	0	0		0	
Days lost							

Direct Employees							
Number of Emp	Number of Employees: Exposure Hours:						
Subcontractors	Subcontractors						
on Site							
	Category 1	Category 2	Category 3	Major Incident	Near Miss		
Number of							
Accidents	0	0 0 0 0					
Days lost	1						

ARP7/4 INSERTED HERE IF AN ACCIDENT OR INCIDENT HAS OCCUERD (USE PHOTOCOPY OF EPS FORM HS002)

Page 7 of 10	



Date	17/11/2021
Description	Initial Issue
Approved By	
Originator	

6. Complaints Register

No written complaints were received during this monitoring period

Complaints Register					
Complainant's Name	Date				
Nature of Complaint					
Acknowledgement of Complaint	Author of Acknowledgement	Date Sent			
Cause of Complaint					
Action taken to Resolve cause of Complaint:					
Final Outcome Report	Author of Final Outcome Report	Date Forwarded to Local Authority			

7. Equipment Calibration Records

	Equipment Calibration Record						
Date Equipment Serial No. Calibrated By Next Calib. Calib. Cert Comment (Name & Company) Due Recd.						Comment	
			Nothing to report				

Page 8 of 10	



Date	17/11/2021
Description	Initial Issue
Approved By	
Originator	

8. Waste & Sludge Disposal Records

	Non-Sludge Waste Disposal Record							
Date	Waste Description	Amount removed	Removed By (Name & Company)	Destination Address	Receipt for Acceptance of Waste			

	Outgoing Sludge Record							
Batch No. Date Destination of Type of Quantity of Product Product Product Contact at Destination								
					Nothing to Report			

9. Analysis Results for Mixed Liquor

Analysis Results for Mixed Liquor (mg/l)							
Date	Date MLSS MBR 1 Anoxic 1 MLSS MBR2 Anoxic 2						
05/10/2021	12,790						
27/10/2021	13,140	12,910					

Page 9 of 10



Date	17/11/2021
Description	Initial Issue
Approved By	
Originator	

10. Analysis Results for Influent

Analysis Results for Influent							
Date	BOD (mg/l O ₂)	COD (mg/l O ₂)	SS (mg/l)	Total Nitrogen (mg/l)	Ammonia (mg/l)	Total Phosphorous (mg/l)	рН
04/10/2021	862	2,470	810		217	15.3	8.4
Maximum for month	862	2,470	810		217	15.3	8.4
Average for month	862	2,470	810		217	15.3	8.4
Design values	220		170		105	11.2	

11. Analysis Results for Final Effluent

Analysis Results for Final Effluent							
Date	BOD (mg/l O ₂)	COD (mg/l O ₂)	SS (mg/l)	Total Nitrogen (mg/l)	Ammonia (mg/l)	Total Phosphorous (mg/l)	рН
04/10/2021	2	47	5		0.094	11.2	7.73
Average for month	2.0	47	5.0	N/A	0.09	11.20	7.7
Licence limit	15	100	15	15	5	2	6 to 9

Page 10 of 10	