

eps	System Procedure Monthly Status Report Cliffs of Moher, April 2022	Date 04/05/2022 Description Initial Issue Approved By
1. INTRODUCTION		3
2. EXECUTIVE SUMM	IARY	3
3. GRAPHICAL PRES	ENTATION OF DATA	4
4. PROCESS AND OF	PERATIONAL ISSUES	7
5. HEALTH & SAFET	Y ISSUES	7
6. COMPLAINTS REC	GISTER	8
7. EQUIPMENT CALI	BRATION RECORDS	8
8. WASTE & SLUDGE	DISPOSAL RECORDS	9
9. ANALYSIS RESUL	TS FOR MIXED LIQUOR	9
10. ANALYSIS RESU	TS FOR INFLUENT	10
11. ANALYSIS RESUL	TS FOR FINAL EFFLUENT	10
	Page 2 of 10	



1. Introduction

This report covers the period of April 2022 for the operation of Cliffs of Moher Wastewater Treatment Plant by EPS, on behalf of Cliffs of Moher Visitor Experience.

2. Executive Summary

The plant processed 509 m3 of effluent for the month, at an average daily flow of approximately 17 m³/day during March.

The influent results for April 12th showed that the Incoming wastewater was not in compliance with the plant design specification for BOD, Ammonia and Total Phosphorus which was in excess of design criteria.

The final effluent results from the 12th of April show that Total Phosphorus and Ammonia was not in compliance as per contract conditions.

The Plant Operator has been adding Water at the Inlet Screen and Molasses to sustain the MLSS Levels at the plant.

Page 3 of 10	




Date04/05/2022DescriptionInitial IssueApproved ByOriginator

3. Graphical Presentation of Data

Table of total daily flows for April 2022 MBR's					
Date	MBR Flow #1 (m ³)	MBR Flow #2 (m ³)	Total Flow		
01/04/2022	13	0	13		
02/04/2022	10	0	10		
03/04/2022	9	0	9		
04/04/2022	8	0	8		
05/04/2022	9	0	9		
06/04/2022	13	0	13		
07/04/2022	13	0	13		
08/04/2022	12	0	12		
09/04/2022	16	0	16		
10/04/2022	16	0	16		
11/04/2022	13	0	13		
12/04/2022	14	0	14		
13/04/2022	27	0	27		
14/04/2022	27	0	27		
15/04/2022	24	0	24		
16/04/2022	24	0	24		
17/04/2022	23	0	23		
18/04/2022	23	0	23		
19/04/2022	13	0	13		
20/04/2022	13	0	13		
21/04/2022	21	0	21		
22/04/2022	22	0	22		
23/04/2022	17	0	17		
24/04/2022	17	0	17		
25/04/2022	18	0	18		
26/04/2022	16	0	16		
27/04/2022	16	0	16		
28/04/2022	21	0	21		
29/04/2022	21	0	21		
30/04/2022	20	0	20		
Average	17	0	17		

Page 4 of 10





System Procedure Monthly Status Report Cliffs of Moher, April 2022

Date04DescriptionIniApproved ByOriginator

04/05/2022 Initial Issue

Table of Cumulative Hours Run

	27/03/2022	01/05/2022	Ave Daily Usage
			Hours
Inlet screen	31,786	31,906	4.14
Inlet pump 1	4,464	4,480	0.55
Inlet pump 2	5,207	5,226	0.66
Balance tank 1,pump 1	6,450	6,646	6.76
Balance tank 1,pump 2	6,959	6,963	0.14
Anoxic mixer no. 1	98,365	99,201	28.83
Anoxic mixer no. 2	55,422	55,422	0.00
Membrane pump 1 (RAS)	91,109	91,933	28.41
Membrane pump 2 (RAS)	51,872	51,877	0.17
Sludge holding tank mixer	4,072	4,072	0.00
Odour fan no. 1	59,806	59,806	0.00
Odour fan no. 2	71,234	72,072	28.90
Forward feed no.1	10,368	10,368	0.00
Forward feed no.2	16,607	16,682	2.59
Drainage pump	1,114	1,115	0.03
Balance tank 2, pump no.1	7,004	7,004	0.00
Balance tank 2, pump no.2	16,896	16,896	0.00
Air Blower 1	20,109	20,109	0.00
Air Blower 2	57,896	57,896	0.00
Air Blower 3	2,717	3,543	23.66
Air compressor	16,311	17,150	28.93
Ultraviolet system	60,978	60,978	0.00

Page 6 of 10



4. Process and Operational Issues

	Process and Operational Issues					
Date	Description of Process Operational Issue	Implemented by				
	Nothing this month					

5. Health & Safety Issues

Site Safety Induction Report						
Contractor Name Contract Number						
Date	Inductor	Inductee	Inductee Signature	Inductee Company		
No	Site Safety	Inductions were u	Indertaken during this m	onitoring period		

Health & Safety Statistics Report						
Plant Manager Date May-22						
Plant Manager			Dale	May-22		
For Period	April-22					
Site Involved	Cliffs of Moher WWTP	_				
Category 1: Covers Fatali	ties and major Injuries					

Category 2: Covers lost time accident resulting in more than 3 days absence Category 3: Covers lost time accidents resulting in 3 days absence or less

Major Incident: Accident not covered by categories 1 to 3

Direct Employees							
Number of Emp	Number of Employees: 1 Exposure Hours: 32hrs						
	Category 1	Category 2	Category 3	Major Incident	Near Miss		
Number of							
Accidents	0	0	0	0		0	
Days lost							

	Direct Employees						
Number of Emp	oloyees:		Exposure H	ours:			
Subcontractors							
on Site							
	Category 1	Category 2	Category 3	Major Incident	Near Miss		
Number of							
Accidents 0 0 0 0 0							
Days lost							

ARP7/4 INSERTED HERE IF AN ACCIDENT OR INCIDENT HAS OCCUERD (USE PHOTOCOPY OF EPS FORM HS002) Page 7 of 10



6. Complaints Register

No written complaints were received during this monitoring period

	Complaints Register					
Complainant's Name	Date					
Nature of Complaint						
Acknowledgement of Complaint	Author of Acknowledgement	Date Sent				
Cause of Complaint						
Action taken to Resolve cause of Complaint:						
Final Outcome Report	Author of Final Outcome Report	Date Forwarded to Local Authority				

7. Equipment Calibration Records

	Equipment Calibration Record						
Date	Date Equipment Se		Calibrated By (Name & Company)	Next Calib. Due	Calib. Cert Recd.	Comment	
			Nothing to report				
			Page 8 of 10				
				•			



8. Waste & Sludge Disposal Records

	Non-Sludge Waste Disposal Record						
Da	ate	Waste Description	Amount removed	Removed By (Name & Company)	Destination Address	Receipt for Acceptance of Waste	

Outgoing Sludge Record						
Batch No.	b. Date Destination of Type of Quantity of Product Product Octated Product Product					
					Nothing to Report	

9. Analysis Results for Mixed Liquor

Analysis Results for Mixed Liquor (mg/l)						
Date	MLSS MBR 1	Anoxic 1	MLSS MBR2	Anoxic 2		
12/04/2022	15,576	13,528				
26/04/2022	15,660	17,450				

Page 9 of 10	

Date	04/05/2022
Description	Initial Issue
Approved By	

10. Analysis Results for Influent

		ł	Analysis Result	s for Influent			
Date	BOD (mg/l O ₂)	COD (mg/l O ₂)	SS (mg/l)	Total Nitrogen (mg/l)	Ammonia (mg/l)	Total Phosphorous (mg/l)	рН
12/04/2022	658	2,060	144	401	306	24.8	9.1
Maximum for month	658	2,060	144		306	24.8	9.1
Average for month	658	2,060	144		306	24.8	9.1
Design values	220		170		105	11.2	

11. Analysis Results for Final Effluent

Analysis Results for Final Effluent							
Date	BOD (mg/l O ₂)	COD (mg/l O ₂)	SS (mg/l)	Total Nitrogen (mg/l)	Ammonia (mg/l)	Total Phosphorous (mg/l)	pН
12/04/2022	5	41	6	38.3	32.3	3.59	7.7
Average for month	5.0	41	6.0	N/A	32.30	3.59	7.7
Licence limit	15	100	15	15	5	2	6 to 9

Page 10 of 10	