



COMHAIRLE | CLARE
CONTAE AN CHLÁIR | COUNTY COUNCIL

Our Ref: WP 151

23rd November, 2022.

Clare County Council,
Cliffs of Moher,
Liscannor,
Co. Clare.



Re: Site Inspection Report WP 151

A Chara,

Please see below the site inspection findings for routine monitoring carried out by Clare County Council environment staff on 27th July 2022, at the Cliffs of Moher Visitor Centre Ltd, licensed pursuant to Section 4 of the Local Government (Water Pollution) Acts, 1977 /1990 as amended.

Preliminary details:

Licensee Name:	Cliffs of Moher Centre
Licence Ref No:	WP 151
Date of Inspection:	27/07/22
Time:	10:30
Clare County Council Representative:	Patricia O'Brien Environmental Technician I

Site Inspection Findings:

Parameter	Result mg/l	Licence Limit mg/l
	27/07/22	
pH (pH units)	7.73	6-9 pH units
BOD (mg/l)	20	15mg/l O₂
COD (mg/l)	35	100mg/l O₂
Suspended Solids (mg/l)	3	15mg/l SS
Ammonia mg/l N	64	5mg/l N
Ortho-phosphate (mg/l P)	9	-


An Roinn Chomhshaoil
An Stiúarthóireacht Forbairt Fhisiceach
Áras Contae an Chláir, Bóthar Nua, Inis, Co. an Chláir, V95 DXP2

Environment Department
Physical Development Directorate
Áras Contae an Chláir, New Road, Ennis, Co. Clare, V95 DXP2

Results of the effluent sample taken on 27th July 2022 are **not in compliance** with the Ammonia licence limits set down in WP 151.

If you have any further queries, please contact Patrick Mullane at pmullane@clarecoco.ie

Mise le meas,



**Clare McGrath,
Staff Officer.**

Please note: This report does not imply full compliance with other conditions of WP 151 during the site inspection. The report only relates to the conditions listed above.