

## Incident INCI010621 for Causeway Licence (A0098-01)

**Notification No:** INCI010621

Submitted: 05/08/2016 12:10

---

### Licensee Details

---

**Organisation:**

Uisce Éireann

**Licence Name:**

Causeway

**Reg No:**

A0098-01

**Site Address:**

Kerry

---

### Notifier Details

---

**Name:**

Sean Culhane

**Address:**

Irish Water Colvill House, Dublin, Ireland

**Phone:**

01-892 5918

**Email:**

sculhane@water.ie

---

### Details

---

**Description of Incident:**

*ELV Exceedence*

**Incident Category:**

Category 1

**Approximate Start of  
Incident:**

24/04/2016 10:23

**First Noticed:**

04/08/2016 10:23

**Still Ongoing:**

No

**End Date:**

04/08/2016 00:00

**New or Recurring Incident:**

New

**Incident Nature:**

Other

**Impact of Incident on Environment:**

No known impact

**Uncontrolled Release to Receptors:**

Water

**Details of any Vulnerable Receptors:**

None

**Likely Cause:**

Plant or equipment maintenance at WWTP

WWTP Required Desludging

**Incident Location**

---

**Licensed Discharge Point:** Yes

**Location Description:**

**Emission Parameter Results**

---

**Communication**

---

**EPA Informed by Telephone:** No

**EPA Informed Date:**

**EPA Informed Staff Member:**

**EPA Informed Contact Details:**

**Other Communications:**

Notified	Contact Details / Telephone	Date
Inland Fisheries Ireland	Email	05/08/2016 10:40

**Additional Details**

---

**Activity in Process at time of incident:**

Normal Plant Operation

**Corrective Actions Taken:**

Action	Name	Date
Desludge WWTP		06/05/2016 12:00

**Preventive Actions to be Taken:**

Action	Target Date
Desludging WWTP	06/05/2016 00:00

**Likelihood of Recurrence:** Medium

**Other Relevant Information**

Parameter	Value	Unit of Measurement	Type	Date
cBOD	28	mg/l	Grab	21/04/2016
TSS	49	mg/l	Grab	21/04/2016

